

Air Permeability Test Certificate

Test number 71303 BINDT registration number 0064
Report reference number ATT/13/028

This is to certify that the following dwelling and test results were carried out fully in compliance with Approved Document L1a of the 2006 Building Regulations

Dwelling plot/address

House/plot number and road name 2a Blue Anchor Way
Town Filey
County North Yorkshire
Country England
Post Code

Unit Type Four Bedroom Detached House

Test Date 1st July 2013 Test Time 09.11

Design air permeability	5.0	m ³ /(h.m ²)	r ² =	0.9968	(>0.98)
Measured air permeability	3.50	m ³ /(h.m ²)	n =	0.6298	(1≥n≥0.5)
Envelope area of dwelling	415				

Accredited Tester

Name Alan Atkinson Signature  Organisation CSS Yorkshire Ltd

Telephone number 01964 529080 E-mail a.atkinson@cssyorkshire.com

Carried out for Essential Vivendi (Developer/owner/other)

Town Filey
County North Yorkshire
Country England



This certificate is issued in compliance with the Competent/Persons' Scheme administered by the British Institute of Non-Destructive Testing on behalf of the Secretary of State for the Department for Communities and Local Government.