

Air Permeability Test Certificate

Test number 57318 BINDT registration number 0064
Report reference number ATT/14/041

This is to certify that the following dwelling and test results were carried out fully in compliance with Approved Document L1a of the 2006 Building Regulations

Dwelling plot/address

House/plot number and road Plot 392 Blue Anchor Rd
Town Filey
County North Yorkshire
Post Code England

Unit Type Two Bedroom Detached House

Test Date 20th May 2014 Test Time 09.17

Design air permeability	5.0	m ³ /(h.m ²)	r ² =	0.9997	(>0.98)
Measured air permeability	2.56	m ³ /(h.m ²)	n =	0.5649	(1≥n≥0.5)
Envelope area of dwelling	192				

Accredited Tester

Name Alan Atkinson Signature  Organisation CSS Yorkshire Ltd

Telephone number 01964 529080 E-mail a.atkinson@cssyorkshire.com

Carried out for Eco Custom Homes (Developer/owner/other)

Town Catfoss

County East Yorkshire

Country England



This certificate is issued in compliance with the Competent/Persons' Scheme administered by the British Institute of Non-Destructive Testing on behalf of the Secretary of State for the Department for Communities and Local Government.