

Air Permeability Test Certificate

Test number ATT.12.038 BINDT registration number 0064

Report reference number 1

This is to certify that the following dwelling and test results were carried out fully in compliance with Approved Document L1a of the 2006 Building Regulations

Dwelling plot/address

House/plot number and road name (Plot 399). 16 Blue Anchor Way

Town Filey

County North Yorkshire

Country England

Post Code

Unit Type Three Bedroom Detached Beach House

Test Date 11th March 2012 Test Time 09.12

Design air permeability	5.0	m ³ /(h.m ²)	r ² =	0.9989	(>0.98)
Measured air permeability	3.52	m ³ /(h.m ²)	n =	0.5998	(1≥n≥0.5)
Envelope area of dwelling	337				

Accredited Tester

Name Alan Atkinson Signature  Organisation CSS Yorkshire Ltd

Telephone number 01964 529080 E-mail a.atkinson@cssyorkshire.com

Carried out for Essential Vivendi (Developer/owner/other)

Town Filey

County North Yorkshire

Country England



This certificate is issued in compliance with the Competent/Persons' Scheme administered by the British Institute of Non-Destructive Testing on behalf of the Secretary of State for the Department for Communities and Local Government.