

Air Permeability Test Certificate

Test number 57199 BINDT registration number 0064
Report reference number ATT/12/088

This is to certify that the following dwelling and test results were carried out fully in compliance with Approved Document L1a of the 2006 Building Regulations

Dwelling plot/address

House/plot number and road name (Plot 390). 5 Blue Anchor Way
Town Filey
County North Yorkshire
Country England
Post Code

Unit Type Three Bedroom Detached House

Test Date 5th July 2012 Test Time 11.12

Design air permeability	5.0	m ³ /(h.m ²)	r ² =	0.9990	(>0.98)
Measured air permeability	3.69	m ³ /(h.m ²)	n =	0.6298	(1≥n≥0.5)
Envelope area of dwelling	337				

Accredited Tester

Name Alan Atkinson Signature  Organisation CSS Yorkshire Ltd

Telephone number 01964 529080 E-mail a.atkinson@cssyorkshire.com

Carried out for Essential Vivendi (Developer/owner/other)

Town Filey
County North Yorkshire
Country England



This certificate is issued in compliance with the Competent/Persons' Scheme administered by the British Institute of Non-Destructive Testing on behalf of the Secretary of State for the Department for Communities and Local Government.